



IEC 62716:2013

Ammonia corrosion testing of photovoltaic (PV) modules

Confirmation of test results

Ref.: 10002/2024-40490-1

Applicant: aleo solar GmbH
Marius-Eriksen-Str. 1
17291 Prenzlau, Germany

Product: Crystalline silicon terrestrial PV modules

Type: LEO L62YXXX LEO L64YXXX
LEO Black L82YXXX LEO Black L84YXXX
P24YXXX LEO Sol S82YXXX
LEO Sol S62YXXX LEO Sol S84YXXX
LEO Sol S64YXXX LEO-N L64YXXX
LEO-N L62YXXX LEO-N Black L84YXXX
LEO-N Black L82YXXX LEO-N Sol S84YXXX
LEO-N Sol S82YXXX

XXX in the type replaces the rated output of the module (Pmax)
Y in the model designation represents S, denoting different properties of front sheet (glass) or T, denoting different properties of module

Manufacturer: aleo solar GmbH

Standard: IEC 62716:2013

Test conditions: As given in IEC 62716:2013

1st test section: Testing time: 8 h
NH₃ concentration: 6667 ppm
Chamber temperature: 60 °C
Relative humidity: 100 %

2nd test section: Testing time: 16 h
NH₃ concentration: 0 ppm
Chamber temperature: 25 °C
Relative humidity: 36 %

Total testing time: 480 h (20 cycles)



VDE Renewables GmbH

Siemensstr. 30
63755 Alzenau
Germany

Phone +49 69 6308-5300
Fax +49 69 6308-5320

www.vde.com/renewables
renewables@vde.com

Deutsche Bank
IBAN DE14 5007 0010 0235 5006 01
BIC DEUTDEFFXXX

VAT-ID DE815641841
Tax number 204/141/20793

Managing Director: Ansgar Hinz

Location: Alzenau
Registered at the local court Aschaffenburg,
No. HRB 13820



Pass criteria:

Visual inspection:	No findings which may affect safety.
Power degradation:	< 5 %
Dry Insulation:	> 40 MΩm ²
Wet insulation:	> 40 MΩm ²
Ground continuity:	< 0,1 Ω
Bypass diode functionality:	Bypass diodes shall remain functional.

Summary of test results:

Visual inspection: No findings which affect safety.

Maximum power degradation: required < 5 %
measured max. 1,24 %

The measured degradation is below the allowed degradation.

Dry insulation resistance: required min. 20,0 MΩ
measured > 1000 MΩ

The measured dry insulation resistance is above the limit.

Wet insulation resistance: required min. 20,0 MΩ
measured min. 455 MΩ

The measured wet insulation resistance is above the limit.

Ground continuity: required < 0,1 Ω
measured max. 0,0035 Ω


The measured resistance is below the limit.

Bypass diode functionality: Bypass diodes remain functional.

The complete test results and the related bill of materials are given in Test Report No. TRPVM-2024-40490-1.

VDE Renewables GmbH


Dietmar Wald


Arnd Roth

63755 Alzenau, 2024-10-15